



**SCHUYLER COUNTY
WATERSHED PROTECTION AGENCY**

Rural Urban Center
208 Broadway St. Rm 305
Montour Falls, NY 14865
Phone: (607) 535-2208
Fax: (607) 535-2361
Email: watershed@stny.rr.com

Timothy R. Hicks –
Watershed Inspector

James D. Howell –
Watershed Assistant

Sources of Sand Filter Treatment Medium (Filter Sand)
Last updated 01/2007

The facilities listed below have demonstrated the ability to provide filter sand that meets the specifications of Part 75-A of the NYS Sanitary Code and is acceptable for use in sand filter wastewater treatment systems in Schuyler County. The listing does not guarantee continued availability as an approved sand source. This listing is not an endorsement or recommendation, but is provided for convenience for contractors and applicants.

It is the responsibility of the wastewater system installer to use materials that meet the specifications below.

Other sources may be used to provide filter sand if an analysis of the sand, provided to the WPA prior to construction, indicates the sand meets the following specifications:

- Sand must be clean and course
- All material must pass through ¼ inch sieve
- The 10% effective grain size must be between 0.25 mm and 1.0 mm
- The uniformity coefficient (ratio of grain size that is 60% finer than itself to the size which has 10% finer than itself) must be 4.0 or less

The analysis must be performed by an independent laboratory capable of completing the sieve analysis.

Facilities where approved sand may be available:

**Porters Sand and Gravel
Waverly, PA
607-565-3452**

**Narde Paving
Elmira Heights, NY
607-737-7177**

**Angelo's Sand and Gravel
Newfield, NY
607-564-7822**